


























Batterie Zustände

Da bis auf den Cube alle Komponenten des Systems mit Batterien versorgt und betrieben werden, ist eine Kontrolle der Zustände unbedingt notwendig und erforderlich.

Aufgrund unzureichender Ladezustände können unvorhergesehene und ungewollte Betriebssituationen auftreten. So könnte zum Beispiel ein Heizkörperthermostat nicht mehr schließen und Heizen obwohl die Temperatur im Raum 30° beträgt.

Aus diesem Grund gibt es auch einmal im Jahr einen festen Termin (18. Juni) an dem alle Batterien getauscht werden.

Hier die Übersicht der Ladezustände

 Pool-5-6 WT-Pool-5-6 battery	Normal	 8-Port Schalter Karambol	100 %
 Pool-5-6 HKV-Fenster-B battery	Normal	 8-Port Schalter Pool	100 %
 Pool-5-6 HVT-Pool-6-links battery	Normal	 Pool-Sitzecke WT-Pool-Sitzecke battery	Normal
 Pool-5-6 HKV-Pool-6-Rechts battery	Normal	 Pool-Sitzecke HVT-Sitzecke battery	Normal
 Kleine-Billard WT-kleine Billards battery	Normal	 Pool-Treppenhaus WT-Pool-Treppenhaus battery	Normal
 Kleine-Billard HVT-Fenster-D battery	Normal	 Pool-Treppenhaus HVT-Treppenhaus battery	Normal
 Kleine-Billard HVT-Fenster-F battery	Normal	 Pool-Raum-Fenster-Strasse WT Thermostat battery	Normal
 grosse Billards WT-grosse-Billard battery	Normal	 Pool-Strasse HVT-Strasse-Links battery	Normal
 grosse Billards HKV-Fenster-K battery	Normal	 Pool-Strasse HVT-Strasse-Rechts battery	Normal
 grosse Billards HKV-Fenster-R battery	Normal	 Wassermelder-Kueche Battery level	100,0 %
 grosse Billards HKV-Fenster-R-von-BGRW battery	Normal	 Wassermelder-Herren_WC Battery level	23,0 %
 Stuebchen WT-Stuebchen battery	Normal		
 Stuebchen HVT-Fenster-Rechts battery	Normal		
 Toiletten HVT-Damen battery	Normal		

Revision #1

Created 2025-12-20 14:15:08 UTC

Updated 2025-12-20 14:15:10 UTC